





All drawings, regardless of form, are owned by Hidria Rotomatika d.o.o. and are strictly confidential and present copyrights. Intellectual Property Rights as follows rights under the laws of patents, petty patents, design patents and registered designs, copyrights, trade secret rights, and similar exclusive rights in industrial property connected with the drawings are reserved by Hidria Rotomatika d.o.o.. Disclosure to any third party is strictly forbidden.

st družbe Hidria-Rotomatika d.o.o. in predstavljajo poslovno skrivnost in so avtorsko delo.
iz patentov, blagovnih znamk in modelov povezanih z risbami pripadajo družbi Hidria Rotomatika d.o.o..
iz tretjim osebam brez pisnega dovoljenja družbe Hidria Rotomatika d.o.o. je strogo prepovedan.



AD	D	Zamenja se stator sestav 0311-2-1391 z 0311-2-1620, rotor sestav barvan 0311-5-0110 z 0311-5-0227, jarem obdelan 0311-7-6052 z 0311-7-6009 ter 0311-7-6053 z 0311-7-6020, prirobnico 0311-7-6051 z 0311-7-6005, priključna škatla 0300-9-4120 z 0311-9-4115, navodilo za kontrolo motorja z ventilatorjem 0301-1-4250 z 0301-1-4759. Uskladi se naziv ventilatorja, v nalepki z nazivnimi podatki se uskladi nazivne podatke ter spremeni kodo ventilatorja kupca z 9-632000 na 9-632100. Spremeni se verzija artikla z AC v AD. Risba v Windchillu je skladna z risbo v arhivu.	04.05.15	Ivan M.
AC	C	Novi nazivni podatki - prehod na novi lameli. Spremeni se verzija artikla z AB v AC. Risba v Windchillu je skladna z risbo v arhivu.	19.11.14	Jure L.
Verzija Artikla:	Verzija risbe:	Opis spremembe:	Datum:	Izdelal:
Article revision:	DRW Revision:	Description of change:	Date:	Produced:
	DATUM/DATE	IME / NAME	POVRŠINSKA OBD. SURFACE TEXTURE	
KONSTRUIRAL / DRN:	22.04.2015	Uroš Kunc	MATERIAL	
ODOBRIL / APP:	07.05.2015	Ivan Mavri	KODA MATERIALA MATERIAL CODE	
Potrjeno/Approved			MASA: MASS:	
NETOL. MERE/UNTOL DIM.			n71	
NÁZIV: TITLE:			VENTILATOR R11R-3530P-4M-3852	
KODA: CODE:			0311-1-0101	
VERZIJA ARTIKLA: REVISION ARTICLE:			VERZIJA RISBE: DRW REVISION:	

REVENTA

CE

DATE

9-632100 R11R-3530P-4M-3852 0311-4-0191

1~230V 50/60Hz 175/210W 0,80/1,15A 1410/1570RPM

MAX.AMB.60/50° C IP54 INS.CL.155 C=4µF/450V

TH.PROT. ROT.

Opomba:

- Na embalažo dodati nalepko z nazivnimi podatki.
- navodilo za kontrolo ventilatorja 0301-1-4759